

EMERGENCY LIGHTING PERIODIC INSPECTION REPORT

REPORT No: EMPIR-20260603192359

This is to certify that the emergency lighting installation at the address below
complies with the requirements of BS-5266-1:2025

South Petherton Youth Club
South Petherton
Somerset
TA13 5AU

And was deemed to be:

SATISFACTORY

Company issuing this Report

GO Electrical
Laurel Cottage, Brister End
Yetminster
Dorset
DT9 6NH
07828046579
garyoliverelectrical@gmail.com
CPS Enrolment No: 29965

Issued on

27/05/2026

Inspected by

Gary Oliver

Reviewed by

Gary Oliver

Recommended re-test

**1 Year from date of
issue**

Report generated by electraform® certification software 2026 | www.electraform.co.uk

EMERGENCY LIGHTING INSPECTION AND TEST REPORT


For systems designed to BS 5266-1 and BSEN 50172 / BS 5266-8

DETAILS OF THE CLIENT		DETAILS OF THE INSTALLATION	
Reach Alternative Education - - -	- - - Reach Alternative Education	- South Petherton Youth Club South Petherton Somerset TA13 5AU	- - - -
DETAILS OF THE EMERGENCY LIGHTING INSTALLATION AND SYSTEM			
System manufacturer - Tel No - System installer - Tel No -		Luminaire types <input checked="" type="checkbox"/> Non-Maintained <input type="checkbox"/> Non-maintained luminaires, maintained signs <input checked="" type="checkbox"/> Maintained Other types - Responsible person -	System duration 3 hours <input type="checkbox"/> Automatic test fitted Date commissioned 27/05/2026
DETAILS OF ADDITIONS OR MODIFICATIONS TO THE SYSTEM SINCE ORIGINAL INSTALLATION			
Modification Number	Modification date	Modification location	Modification details
DETAILS OF THE COMPANY ISSUING THE COMPLIANCE CERTIFICATE			
Trading title GO Electrical		Postcode DT9 6NH	Company email garyoliverelectrical@gmail.com
Address Laurel Cottage, Brister End		Telephone no 07828046579	Website -
Town Yetminster		Mobile number -	
County Dorset		Enrolment no 29965	
DECLARATION			
Overall assessment of the installation in terms of its suitability for continued use:		SATISFACTORY	
Inspected and tested by Name Gary Oliver Position Electrician		Certificate authorised by Name Gary Oliver Position Electrician	
Signature Date 27/05/2026		Signature Date 27/05/2026	
NEXT INSPECTION			
I, recommend that this installation is further inspected and tested in			1 Year

EMERGENCY LIGHTING INSPECTION AND TEST RECORD

Test date	Test type	Which test	Test result	Engineer	No of faults reported
27/05/2026	Annual	2nd	Pass	Gary Oliver	0

FOR THE INSPECTION AND TESTING OF THE EMERGENCY LIGHTS


Name (Capitals)	Signature	Date
<div>Gary Oliver</div>	<div></div>	<div>27/05/2025</div>

Report produced by electroform® certification software based on the MODEL FORM from BS-5266-1:2025

EMERGENCY LIGHTING FAULT RECORD

Item No	Date of failure	Luminaire reference (if any)	Fault location	Action taken to safeguard premises	Action taken to rectify fault	Date of repair	Engineer
---------	-----------------	------------------------------	----------------	------------------------------------	-------------------------------	----------------	----------

FOR THE RECORDING OF FAULTS AND REPAIRS

Name (Capitals)	Signature	Date
Gary Oliver		27/05/2025