



Devon & Somerset Fire Protection Ltd

1 Tyne Park Blackbrook Taunton
Somerset TA1 2RP
Tel 01823 322925
Mobile 07786 723432



Certificate of Extinguisher Maintenance

Customer

Reach Alternative Education
Lightgate Lane
South Petherton
Somerset
TA13 5AU

Service Address

Reach Alternative Education
Lightgate Lane
South Petherton
Somerset
TA13 5AU

This certificate confirms that we have completed the maintenance service of the fire equipment listed below in accordance with BS 5306-3:2009

Water

Foam 3

Powder

Co2 4

Hose

Wet Chemical

Certificate Number C15849 a

Issue Date 12/09/2025

Signed

R.Smith

Russell Smith: DSfire

Signed

Owner or responsible person

Routine Inspection by the user: BS 5306-3:2009

The user or user's representative should carry out regular visual inspection of all equipment to make sure that:

- a) Each extinguisher is located in the designated place:
- b) Each extinguisher is unobstructed and visible:
- c) The operating instructions of each extinguisher are clean and legible and face outwards:
- d) Each extinguisher has not been operated and is not obviously damaged:
- e) The reading of any pressure gauge or indicator fitted to an extinguisher is within operational and safety limits:
- f) The seals and tamper indicators of each extinguisher are not broken or missing:

The user should arrange for corrective action, where necessary.

Devon & Somerset Fire Protection Ltd:
A British Fire Consortium Audited Company
Established 1991

Please Note: Equipment unfit for service listed overleaf!